



73 OLIVER STREET  
COHOES, NY 12047  
235-0170 477-1094 272-6278

**GAS HEAT  
PEAK PERFORMANCE INSPECTION REPORT**

Date \_\_\_\_\_ Customer \_\_\_\_\_ Phone \_\_\_\_\_

Address \_\_\_\_\_

Brand \_\_\_\_\_ Unit Model \_\_\_\_\_ S# \_\_\_\_\_

- |  |       |     |       |     |
|--|-------|-----|-------|-----|
| Unit running prior to inspection         | _____ | Yes | _____ | No  |
| 1. Visual inspection of heat exchanger   | _____ | Yes | _____ | No  |
| 2. Check replace / clean air filter      | _____ | Yes | _____ | No  |
| 3. Clean blower motor                    | _____ | Yes | _____ | No  |
| 4. Check blower wheel                    | _____ | Yes | _____ | No  |
| 5. Lube motor                            | _____ | Yes | _____ | No  |
| 6. Lube circulator                       | _____ | Yes | _____ | No  |
| 7. Inspect gas line from valve to burner | _____ | Yes | _____ | No  |
| 8. Inspect combustion openings           | _____ | Yes | _____ | No  |
| 9. Inspect flue pipe                     | _____ | Yes | _____ | No  |
| 10. Clean burners                        | _____ | Yes | _____ | No  |
| 11. Boiler PSI                           | _____ | Yes | _____ | n/a |

**Check One**

12. Standing pilot
13. Clean pilot \_\_\_\_\_ Yes \_\_\_\_\_ No
14. Check thermocouple \_\_\_\_\_
15. Adjust pilot \_\_\_\_\_ Yes \_\_\_\_\_ No

- Electronic ignition
- Test ignitor \_\_\_\_\_ ohms
- Test flame sensor \_\_\_\_\_ ua
- Clear pressure tubes \_\_\_\_\_ Yes \_\_\_\_\_ No
- Inducer motor amps \_\_\_\_\_

16. Humidifier \_\_\_\_\_ Yes \_\_\_\_\_ No
17. Change water panel \_\_\_\_\_ Yes \_\_\_\_\_ No
18. Air cleaner \_\_\_\_\_ Yes \_\_\_\_\_ No
19. Test safeties \_\_\_\_\_ Yes \_\_\_\_\_ No
20. Supply temp \_\_\_\_\_
21. Return temp \_\_\_\_\_

- Drain clear \_\_\_\_\_ Yes \_\_\_\_\_ No
- Change media \_\_\_\_\_ Yes \_\_\_\_\_ No
- Test thermostat \_\_\_\_\_ Yes \_\_\_\_\_ No
- Change batteries per customer \_\_\_\_\_ Yes \_\_\_\_\_ No
- Secure panels \_\_\_\_\_ Yes \_\_\_\_\_ No

22.  $\Delta T$  \_\_\_\_\_ Normally 30- 60 degrees

23. Flue temp \_\_\_\_\_ CO2 \_\_\_\_\_ Draft \_\_\_\_\_ CO \_\_\_\_\_ Efficiency \_\_\_\_\_

24. Aluminum boilers \_\_\_\_\_ -PH \_\_\_\_\_ Pass \_\_\_\_\_ Fail Adjusted PH \_\_\_\_\_

Customer has working carbon monoxide detector \_\_\_\_\_ Yes \_\_\_\_\_ No

Unit is working properly \_\_\_\_\_ Yes \_\_\_\_\_ No

**THE FOLLOWING CORRECTIVE ACTION IS REQUIRED:** \_\_\_\_\_

**Additional Comments** \_\_\_\_\_

**Technician's Name** \_\_\_\_\_ **Customer's Signature** \_\_\_\_\_